

AD-A089 269

CIVIL ENGINEERING LAB (NAVY) PORT HUENEME CA  
COGENERATION SYSTEMS.(U)


F/G 13/1

UNCLASSIFIED


JUN 80 E E COOPER  
CEL-TR-879

NL

1 of 1  
AD-A  
786249



END  
DATE  
FILMED  
10-80  
DTIC



MICROCOPY RESOLUTION TEST CHART

AD A089269

12

R879



# TECHNICAL REPORT CIVIL ENGINEERING LABORATORY

Naval Construction Battalion Center, Port Hueneme, California 93043

## COGENERATION SYSTEMS

by

E. E. Cooper, Ph D

June 1980

Sponsored by

NAVAL MATERIAL COMMAND

Approved for public release; distribution unlimited.

STIC  
SEP 18 1980  
A

80 9 18 065

14 -T-

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

| REPORT DOCUMENTATION PAGE   |                                  | READ INSTRUCTIONS<br>BEFORE COMPLETING FORM   |
|---|----------------------------------|---|
| 1. REPORT NUMBER<br>TR-879  | 2. GOVT ACCESSION NO<br>DN987115 | 3. RECIPIENT'S CATALOG NUMBER<br>AD-A029 269  |
| 4. TITLE (and Subtitle)<br>COGENERATION SYSTEMS   |                                  | 5. TYPE OF REPORT & PERIOD COVERED<br>Final; Jul 1979 - Mar 1980                          |
| 7. AUTHOR(s)<br>E. E. Cooper, Ph D  |                                  | 6. PERFORMING ORG. REPORT NUMBER  |
| 9. PERFORMING ORGANIZATION NAME AND ADDRESS<br>CIVIL ENGINEERING LABORATORY<br>Naval Construction Battalion Center<br>Port Hueneme, California 93043  |                                  | 8. CONTRACT OR GRANT NUMBER(s)<br>12  |
| 11. CONTROLLING OFFICE NAME AND ADDRESS<br>Naval Material Command<br>Washington, DC 20360   |                                  | 10. PROGRAM ELEMENT PROJECT, TASK<br>AREA & WORK UNIT NUMBERS<br>64710N;<br>20371-01-141A |
| 14. MONITORING AGENCY NAME & ADDRESS (if different from Controlling Office)<br>9 Final Rept.<br>Jul 79-   |                                  | 12. REPORT DATE<br>June 1980  |
| 16. DISTRIBUTION STATEMENT (of this Report)<br>Approved for public release; distribution unlimited.   |                                  | 13. NUMBER OF PAGES<br>54   |
| 17. DISTRIBUTION STATEMENT (of the abstract entered in Block 20, if different from Report)  |                                  | 15. SECURITY CLASS. (of this report)<br>Unclassified                                      |
| 18. SUPPLEMENTARY NOTES   |                                  | 15a. DECLASSIFICATION/DOWNGRADING<br>SCHEDULE   |
| 19. KEY WORDS (Continue on reverse side if necessary and identify by block number)<br>Cogeneration, heat recovery, total energy systems, coal-fired steam boilers, energy conservation.   |                                  |   |
| 20. ABSTRACT (Continue on reverse side if necessary and identify by block number)<br>Discussions are included of the four broad interrelated categories of factors to consider when evaluating candidate approaches to cogeneration at a site. The categories are technical, economic/financial, legislative/regulatory, and institutional. The inability to resolve difficulties in any area may obviate implementation of cogeneration. Generalized performance curves are presented for cogeneration systems utilizing commercially available<br>(continued) |                                  |   |

DD FORM 1 JAN 73 1473

EDITION OF 1 NOV 65 IS OBSOLETE

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE (When Data Entered)

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)

20. Continued

steam turbines, diesels, or combustion turbines with heat recovery. A summary is given of federal energy and environmental legislation and regulations currently in effect which impact cogeneration systems. The nature of institutional constraints on implementing cogeneration is also discussed. The potential for cooperative ownership/operation options with utility companies or third party investors is described. The economics of cogeneration is detailed. Finally, steps are listed for proceeding through the categories of factors toward implementation of cogeneration.

Library Card

Civil Engineering Laboratory  
COGENERATION SYSTEMS (Final), by E. E. Cooper, Ph D  
TR-879 54 pp illus June 1980 Unclassified

1. Cogeneration 2. Energy conservation I. Z0371-01-141A

Discussions are included of the four broad interrelated categories of factors to consider when evaluating candidate approaches to cogeneration at a site. The categories are technical, economic/financial, legislative/regulatory, and institutional. The inability to resolve difficulties in any area may obviate implementation of cogeneration. Generalized performance curves are presented for cogeneration systems utilizing commercially available steam turbines, diesels, or combustion turbines with heat recovery. A summary is given of federal energy and environmental legislation and regulations currently in effect which impact cogeneration systems. The nature of institutional constraints on implementing cogeneration is also discussed. The potential for cooperative ownership/operation options with utility companies or third party investors is described. The economics of cogeneration is detailed. Finally, steps are listed for proceeding through the categories of factors toward implementation of cogeneration.

Unclassified

SECURITY CLASSIFICATION OF THIS PAGE(When Data Entered)

## CONTENTS

|  | Page |
|--|------|
| PRINCIPLE OF COGENERATION . . . . .  | 1    |
| FACTORS IMPACTING COGENERATION . . . . .                                   | 2    |
| COGENERATION SYSTEM OPTIONS . . . . .                                      | 5    |
| ECONOMIC/FINANCIAL CONSIDERATIONS . . . . .                                | 8    |
| General Economic Concepts . . . . .  | 8    |
| Cost Estimates for Construction and O&M . . . . .                          | 12   |
| Fuel Costs and Fuel Flexibility . . . . .                                  | 13   |
| PERFORMANCE CURVES AND CHARACTERISTICS<br>OF COGENERATION PLANTS . . . . . | 17   |
| ENERGY/ENVIRONMENTAL LEGISLATION AND REGULATIONS . . .                     | 22   |
| INSTITUTIONAL CONSTRAINTS . . . . .  | 25   |
| IMPLEMENTING COGENERATION . . . . .  | 26   |
| REFERENCES . . . . .   | 28   |

|             |  |
|-------------|--|
| As assigned |  |
| By          |  |
| Date        |  |
| Initials    |  |
| Signature   |  |
| Print Name  |  |
| Rank        |  |
| Branch      |  |
| Post Office |  |
| City        |  |
| State       |  |
| Country     |  |
| Remarks     |  |
| Special     |  |

## PRINCIPLE OF COGENERATION

Cogeneration can be an effective means of conserving energy where both thermal energy and electrical energy are needed. Figure 1 illustrates the benefit of cogeneration by comparing energy balances for a conventional system and for an ideal cogeneration system serving a load center that requires simultaneously 200 units of thermal energy and 100 units of electrical energy. In the conventional system, where the thermal energy is supplied by an on-site boiler or a heater with an efficiency of 75%, an input energy of 267 units is required to meet the thermal load. The 100-unit electrical load is met by purchasing power from the utility company at a net efficiency of approximately 33%, so that 300 units of energy are input at the central power plant. The conventional system has an overall, or "universal," efficiency of 53%. By comparison, the depicted cogeneration system is able to meet the same thermal and electrical loads at an overall efficiency of 75% by capturing exhaust heat from an on-site electrical generation process to provide the thermal energy. The relative thermal-to-electrical energy ratio of 2:1 in this ideal example is typical of cogeneration systems using combustion turbines. Other cogeneration systems have different characteristic thermal-to-electric ratios, as illustrated in Figure 2.

Retrofitting a facility for cogeneration usually involves the acquisition of a considerable amount of new equipment for generation of electrical power and capture or utilization of normally "wasted" heat. In fact, "retrofitting" generally requires the actual replacement of significant portions of the old systems that supply electrical and thermal energy, plus adding more capability. Therefore, cogeneration systems typically require carefully considered capital expenditures that will be recovered only if sufficient cost savings in fuel or purchase of electrical power is achieved.

## FACTORS IMPACTING COGENERATION

The process of deciding whether to implement cogeneration and, if so, which system to select, can be a complex one. There are probably more nontechnical than technical factors which impact the outcome of an assessment of cogeneration for a particular site. Many technically sound cogeneration system projects have failed to reach the operational stage because the nontechnical constraints were not anticipated or could not be overcome when encountered. Because of this, it is important that there be an awareness from the outset of the need to identify both the technical and nontechnical issues and ensure that each be given the level of attention required by the decision process.

Factors impacting cogeneration may be put into the following categories:

1. Technical
2. Economic/Financial
3. Legislative/Regulatory
4. Institutional

In some cases, a particular issue or factor relevant to the evaluation of cogeneration may affect two or more categories (e.g., the type of fuel may be restricted by environmental and energy legislation, as well as affecting the technical design of the equipment, the capital costs, and the life cycle economics). Some examples of issues that might arise during the examination of cogeneration are:

1. Technical -

- Load patterns (profiles, magnitudes, driving functions)
- Choice of fuels
- Plant site location relative to loads and condition of distribution systems
- Performance of candidate systems



2. Economic/Financial -

- Magnitude of capital costs
- Impact of fuel choice and other parameters on capital costs, operating costs, ROI
- Available tax incentives
- Marketability of excess power
- Sources of capital, outside versus self-generated
- Utility company standby rates

3. Legislative/Regulatory -

- Local air emissions standards and attainment status
- Waste disposal restrictions
- Jeopardy of any environmentally protected areas
- National fuel use and energy legislation
- State PUC facilities regulations regarding cogeneration
- Status of PUC jurisdiction over regulation of cogeneration facilities
- Zoning or siting restrictions

4. Institutional -

- Utility company policies toward cogeneration
- Availability of personnel and skills for operation and maintenance of system
- Assessment of impact on facility mission
- Assessment of impact on special requirements, (e.g., security)
- Impact on community
- Impression on community

Some of the more important factors are discussed below. Guidance is also provided for sources of information and data for a number of the questions which may arise.

The key requirement for a successful cogeneration application is to use the recovered "waste" heat beneficially. Heat recovery can be accomplished on engines driving electrical generating equipment or on engines producing mechanical shaft power, but the incorporation of heat recovery equipment is uneconomical unless a substantial portion of the heat is used.

A good energy survey of a facility provides the basic information needed to determine if load conditions are favorable for cogeneration. An energy survey should examine the thermal loads, the electrical loads, and the mechanical shaft loads. It is recommended that this energy survey include the following information about the various loads:

### Thermal Energy

Present thermal energy usage profiles and demand levels; include extremes

Existing thermal supply system characteristics/capacity, pressure, temperature; include purchases

Condition and coverage of thermal distribution system

Major thermal loads and thermal state of energy required

Opportunities for conserving and reducing thermal energy usage

### Electrical/Mechanical Shaft Energy

Present electrical energy usage profiles and demand levels; include extremes

Identification of any on-site electrical generating units and/or large motors or engines providing mechanical shaft power; include the output levels and profiles

Opportunities for conserving and reducing electrical energy usage

In addition, it is recommended that an energy audit include consideration of:

- Planned changes in operations or functions at the facility which would impact load profiles, demand levels, or capability to meet loads
- Opportunities to alter loads to benefit cogeneration potential

The data and information accumulated during the energy survey should be applied in the following way in preparation for the cogeneration assessment.

1. Estimate the loads after implementation of energy conservation measures.

2. Determine if the resulting thermal load is high enough to warrant cogeneration. Reference 1 recommends having a process heat load of at least 200 to 300 million Btu/hr, at which level diesels or combustion turbines with exhaust heat boilers would normally be used, or even higher for use of steam turbines.

3. Establish representative profiles which account for diurnal and seasonal effects, or other significant effects, such as process variations. In general, the potential for cogeneration is enhanced when electrical and thermal load patterns are similar and in phase.

## COGENERATION SYSTEM OPTIONS

There are usually numerous cogeneration system alternatives for consideration at a site that stem from the basic questions:

1. What types of power plant should be used?
2. What capacity should the system have?

Commercial equipment (Figure 3) is readily available for four generic types of cogeneration systems: diesel engine systems, combustion turbine systems, steam turbine systems, and combined cycle systems. Other options, such as the organic Rankine bottoming cycle, are on the threshold of commercialization, but the sparse data base and experience level with them preclude their inclusion in this report. The selection of a system for a particular installation depends on many site specific factors that ultimately affect cost. One very important factor is how the system ratio of thermal/electrical output, which was addressed in Figure 2, matches that of the loads. Other important factors include types of fuel available, environmental restrictions, utility rate structures, etc. Further discussions of the performance of each type of system and other characteristics influencing selection are given in the sections below.

The size, or capacity, of a cogeneration system obviously depends upon the thermal and electrical loads to be served. As seen below, the electrical load may be considered "infinite" if the system is allowed to transfer power to the grid. This type of system can operate at its most efficient or economical point because it can sell power to the grid if the system electrical output exceeds the facility's electrical load. As a rule of thumb, the best overall efficiency for meeting the thermal and

electrical loads will be obtained if the cogeneration system is sized to meet the typical or average thermal load. Fluctuations in loads cause the system to almost always operate at off-design points. The load swings and other factors result in compromises when deciding system capacity.

Figure 4 depicts cogeneration systems in a generalized sense and illustrates how backup capability or additional capacity to meet the thermal and electrical loads may be provided by fired auxiliary boilers and utility grid connections, respectively. The connection to the utility company grid is a very important and, in most cases, very beneficial feature for a cogeneration system. First, because the grid can carry part of the electrical load, the option exists to size the cogeneration system with respect to the thermal load if that appears to yield the best economy or fuel efficiency. Second, because the grid "backs up" the cogeneration system, standby and emergency electrical generating capacity do not have to be installed as part of the system, thus reducing capital costs. Third, the utility company or customers connected to the grid become potential markets for power generated in excess of that needed to meet the on-site electrical load. And fourth, a reliable cogeneration system adds to the total capacity of the utility company so that there becomes an incentive for the utility company to consider partial or total ownership and/or operation of the cogeneration system.

There are five basic types of cogeneration system arrangements that have progressive degrees of utility company or third party involvement. They are:

1. Navy ownership and operation of an under-capacity plant. The utility sells power to the facility to make up the difference between the electrical load and the capacity of the cogeneration plant.
2. Navy ownership and operation of an over-capacity plant. The utility purchases power from the facility in excess of that needed to meet the load.
3. Navy ownership with utility operation of the plant.

4. Utility/Navy joint venture in a cogeneration plant. This involves a mutually acceptable sharing of capital costs and operating responsibilities. A joint venture may also be arranged between the Navy and some third party other than the utility.

5. Utility or third party ownership and operation of a cogeneration plant. The utility or third party markets both thermal and electrical energy to the facility.

The degree to which a utility is willing to participate depends upon its needs and policies and varies from one utility to another. There is growing acceptance of cogeneration system connections to the grid and a trend toward cooperative participation by utilities as a result of demand growth, difficulties in providing new central plant capacity, and legislative or regulatory measures favoring cogeneration.

The degree to which the Navy is willing to participate in a cooperative venture or give up some responsibility for the utility system, particularly steam, likewise varies from one location to another. There may be growing acceptance of non-Navy involvement in the "steam side" of utility service at bases because of pressures to contract out more services, difficulties and delays in obtaining sufficient MILCON funding for cogeneration or coal conversion projects, and precedents set elsewhere.

If consideration is being given to a joint cogeneration venture at a particular Navy site, it is well to remember that each party has the fundamental responsibility to assess the economics and operational characteristics of alternatives from the perspective of its own needs and to determine conditions under which it would be willing to participate in a cooperative venture. The acceptability of these conditions to the other party is subject to the results of efforts to establish "Agreements in Principle" and subsequently to negotiation of a contract.

## ECONOMIC/FINANCIAL CONSIDERATIONS

### General Economic Concepts

An investor, whether it be the Navy, a utility company, or a third party, considering the financing of a cogeneration system is concerned with numerous factors and their impact on the economic projections for the system. The total annual cost of providing thermal plus electrical utility service to a facility is expressed as the summation of several basic contributing factors.

$$TC_j(y) = CC_j(y) + F_j(y) + OM_j(y) + P_j(y) - R_j(y)$$

where (y) = annual costs as a function of time (i.e., year)

j = costs occurring if alternative "j" is chosen to supply utility services

TC = total cost for thermal plus electrical services

CC = capital cost expenditure, including interest on funds during construction

F = fuel costs

OM = operation and maintenance costs

P = cost of payment for energy purchased from outside (electrical or thermal) or for service purchased from outside

R = any revenues resulting from operation and/or ownership of equipment at the facility

Cost estimates for future years necessitate estimating escalation rates for fuel, electricity, O&M, etc. Since the "crystal ball" is uncertain, escalation rates are sometimes varied parametrically, and the sensitivity of the economic projections to the variations is determined.

A cooperative, or joint, venture requires the mutual approval of the utility company or another outside party as well as the Navy in order to be implemented. Where there is the prospect for a cooperative venture, either in ownership or operation or both for a new system, it is perhaps more definitive to generalize the expression for total annual cost  $TC_j(y)$  to reflect the economics of alternative approaches from the perspective of each participant.

$$TC_{nj}(y) = CC_{nj}(y) + F_{nj}(y) + OM_{nj}(y) + P_{nj}(y) - R_{nj}(y)$$

where n indicates that the cost term is from the perspective of a single participant. All other symbols are identified above.

Each participant would apply only the portion of capital costs, operation and maintenance costs, etc., incurred as its responsibility, and revenues it would realize.

Different alternatives for providing the necessary utility services would be compared by each party. One alternative may reduce fuel costs, but increase capital costs. Another may involve a larger plant which increases both fuel and capital costs, but results in revenues through sale of excess power to offset the increases. In the economic analyses of alternative options, the term "alternative" indicates not only different design options (such as steam turbines versus combustion turbines), but it also indicates different ownership/operation arrangements or even different means of financing the construction costs. For example, suppose that consideration of load patterns, fuel availability, and other items has resulted in the conclusion that a 20 MWe coal-fired extraction/ condensing steam turbine system is the best design to meet the utility needs of a given facility. Discussions with the local utility company, however, reveal that it would be open to cooperating in any of three ways: (1) owning and operating the entire cogeneration plant and selling both steam and electrical power to meet the facility needs; (2) owning and operating only the electrical generation portion of the cogeneration plant, with provisions for extracting steam needed for the facility, and continuing to provide electrical service; or (3) not owning or operating any part of the cogeneration plant, but selling power to the facility as needed or buying excess power from the cogeneration plant. Therefore, these are three distinct alternatives to be evaluated economically, based upon details to be negotiated and worked out with the utility company.

The cost components making up  $TC_{nj}(y)$  provide the information needed by the Navy and potential outside investors to decide upon the economic viability of an option. Principally, each party is concerned

with its own Return on Investment (ROI), with the magnitude and means of handling its portion of the capital expenditure, and with the total life cycle savings it will realize from each alternative.

Continuation of conventional service is usually the baseline against which cogeneration alternatives are compared. A typical scenario for continuing conventional service is that new boilers would be acquired by the Navy in some future year, steam would be supplied from on-base boilers, all electrical energy would be purchased from the utility company, and no electrical power would be generated on-base. Therefore,  $CC_{n,conv}(y) = 0$  except for the year new boilers are purchased; then,  $CC_{n,conv}(y) = \text{cost of boilers}$ .  $F_{n,conv}(y) = \text{annual boiler fuel cost}$ ;  $OM_{n,conv}(y) = \text{annual boiler operation and maintenance costs}$ ;  $P_{n,conv}(y) = \text{cost of electrical energy purchased from the utility}$ ; and  $R_{n,conv}(y) = 0$ . The annual savings for the Navy from operation of an alternative to the conventional system (i.e., exclusive of the handling of the capital outlay) is

$$S_{nj}(y) = [TC_{n,conv}(y) - TC_{nj}(y)] - [CC_{n,conv}(y) - CC_{nj}(y)]$$

A similar expression for savings could be written for each party in a cooperative venture.

Return on Investment is a common measure of judging economic viability of candidate investments. A minimum ROI must be exceeded to gain approval for an investment. A minimum acceptable ROI is set by the investor himself, and depends on the type of investment being made. The acceptable ROI is a function of the economic life for the investment, which is also established by the investor. Substituting the minimum ROI into the expression below, the total savings to be realized must exceed the net capital expenditures. Otherwise the project is not viable.

$$\sum_{y=0}^{y=EL+N} \frac{[CC_{nj}(y) - CC_{n,conv}(y)]}{(1 + ROI_{nj})^y} \leq \sum_{y=N+1}^{y=EL+N} \frac{S_{nj}(y)}{(1 + ROI_{nj})^y}$$



where  $CC_{nj}(y)$  = annual construction payments made for designated project by participant "n"

$N$  = number of years from beginning of construction financing to startup of alternative system

$EL$  = economic life of alternative system

$S_{nj}$  = annual savings resulting from operation of the system by party "n"

It is quite often the case that  $CC_{n,conv} = 0$  for all years through the economic life of the alternative system (i.e., if the conventional system was retained, no capital expenditure would be required). Removing the inequality and assuming  $CC_{n,conv} = 0$ , the commonly used expression for ROI is obtained

$$\sum_{y=0}^N \frac{CC_{nj}(y)}{(1 + ROI_{nj})^y} = \sum_{y=N+1}^{y=EL+N} \frac{S_{nj}(y)}{(1 + ROI_{nj})^y}$$

It is deduced from the definitions that ROI is analogous to the discount rate which the Navy prescribes to convert future savings or expenditures into present values. As used by the Navy, the discount rate is considered to be the rate of return over and above the inflation rate. Consequently, escalation rates of fuel costs, O&M costs, etc., are designated as price increases over and above those required to keep up with inflation. Utility companies or other firms often choose instead to include inflation in their return on investment, and appropriately account for inflation in the other terms also.

The discounted Savings-to-Investment Ratio (SIR), frequently used by the Navy to assess the viability of a project, is obtained by setting  $ROI = 0.10$  and calculating the ratio of the right-hand side (savings) of the above equation to the left-hand side (investment). In general,

$$SIR = \frac{\sum_{y=N+1}^{y=EL+N} \frac{S_{nj}(y)}{(1 + ROI_{nj})^y}}{\sum_{y=0}^{y=EL+N} \frac{[CC_{nj}(y) - CC_{n,conv}(y)]}{(1 + ROI_{nj})^y}} \geq 1$$

Strictly speaking, return on investment applies only to projects which involve capital investment. Some alternatives may be based upon measures not involving capital expenditure. It is beneficial to account for the declining value of money by discounting the future expenditures in such cases also. The Navy chooses to discount at 10% over inflation in all cases, but some business might elect to use a different discount rate where capital expenditure is not involved. Drawing an analogy from the inequality defining ROI, and substituting for  $S_{nj}(y)$ , it is concluded that an alternative is viable when its discounted total life cycle cost is less than that of the conventional approach.

$$\sum_{y=0}^{y=EL+N} \frac{TC_{nj}(y)}{(1 + d_{nj})^y} \leq \sum_{y=0}^{y=EL+N} \frac{TC_{n,conv}(y)}{(1 + d_{nj})^y}$$

where  $d_{nj}$  = discount factor used by participant "n" for the particular type of expenditure involved

The Navy, or course, is able to perform economic assessments of cogeneration alternatives at a selected site from its own perspective most adequately. There is less likelihood, however, of the Navy being able to adequately perform an economic assessment from the perspective of a potential co-participant in a joint venture because some essential input might be unavailable.

#### Cost Estimates for Construction and O&M

Determination of  $ROI_j$  requires knowledge of construction costs, length of construction period, and the factors ( $F_j$ ,  $OM_j$ ,  $P_j$ , and  $R_j$ ) contributing to the savings  $S_j$ . Data from References 1 and 2 are provided below which should be helpful in making rough planning estimates of construction costs, construction schedules, and O&M costs for various types of cogeneration plants. The information presented below is typical of mid-1978 costs, so projections of construction and O&M costs for future years should be made on the basis of an appropriate Construction Cost Escalation Factor and Labor Rate Escalation Factor.

Figures 5 through 8 provide cost estimating data for coal-fired steam turbine systems. A coal-fired plant is composed of the steam-generating section; the turbine/generator section, which may be either a backpressure unit or an extraction-condensing unit; the coal- and ash-handling facilities, which may involve open coal piles or storage of the coal in concrete silos; and the air pollution control equipment, which includes a baghouse and sulfur removal provisions, if necessary. The construction cost for a complete coal-fired plant is the sum of applicable costs.

Figures 5, 6, and 8 also provide cost estimating data for oil- and natural gas-fired steam turbine systems. Figure 5 shows the steam-generating station of an oil-fired plant to be less expensive than that of a coal-fired plant of equal capacity. On the other hand, the cost of the turbine section is independent of the type of fuel used. An oil-fired facility may need a sulfur stack removal unit if high sulfur oil is burned.

Figure 9 shows representative construction costs for combustion turbine and diesel cogeneration plants. These are made up of the engine/generator sets plus exhaust heat boilers, and include water treatment system, switchgear, foundations, and control panel costs. Costs for these systems are primarily just a function of engine rating.

Figure 10 indicates representative construction schedules for various types of cogenerating plants.

Estimating procedures for operating and maintenance costs are summarized in Table 1, which refers to Figures 11 through 15 for determining portions of the costs attributed to several components of steam turbine systems.

#### Fuel Costs and Fuel Flexibility

Over the operating life of a cogeneration system, fuel is often the largest contributor to the ownership and operation of the system. For systems burning oil or natural gas, fuel will typically constitute 65-90% of the total life cycle cost for the system, and will be a significant portion of the annual total utility cost,  $TC_j$ . For economic reasons, therefore, it is advisable to consider cogeneration plant designs that

burn less expensive fuels and have the flexibility to handle various fuels where it appears two or more fuels may be competitive. The high cost of petroleum fuels and the likelihood of further rapid price escalations are making oil-fired systems difficult to economically justify in many installations. Natural gas may maintain some cost advantages over oil, but it also is a premium fuel, likely to become in short supply and undergo rapid price increases. Coal-fired systems require a larger capital expenditure to install, but the anticipated lower fuel costs will often more than offset the greater initial outlay. Flexibility to burn other fuels can usually be incorporated into the design of a coal-fired plant at relatively low cost. For example, solid waste might be substituted for a portion of the coal if the furnace volume is slightly increased and additional storage capacity is provided. Or oil- or natural gas-firing capability can be added to a coal-firing facility at minimum cost.

Since fuel cost is such an important contributor to the economic feasibility of cogeneration systems, it is beneficial to quickly determine the contribution which fuel makes to the cost of electrical power from a cogeneration system. Figure 16 shows how fuel cost impacts the cost of power generated on-site. In a cogeneration system, additional fuel is required over the amount needed to produce only the steam. The effective heat rate for power production from the cogeneration system is

$$HR_{EFF} = \frac{\dot{F}_{COGEN} - \dot{F}_{SO}}{\dot{E}}$$

where  $HR_{EFF}$  = effective heat rate, Btu/kW-hr

$\dot{F}_{COGEN}$  = fuel flow rate to the cogeneration system, Btu/hr

$\dot{F}_{SO}$  = fuel flow rate that would be used by boiler  
producing only steam, Btu/hr

$\dot{E}$  = power production from the cogeneration system, kW

Table 1. Estimating Procedures for Operating and Maintenance Costs for Cogeneration Systems

| Potential Contributor to O&M Costs  | Estimating Procedure or Figure  |
|---|---|
| <b>A. Steam Turbine Cogeneration Plants, Coal-Fired</b>                     |   |
| Central Receiving and Handling Facility                                     | Figure 11 <sup>a</sup>  |
| Hauling, Receiving Facility - Generating Plant (if not co-located)          | Figure 12 <sup>a</sup>  |
| Steam Generating Facility   | Figure 13 <sup>a</sup>  |
| Air Pollution Control System  | Figure 14 <sup>a</sup>  |
| Electrical Generating Facility  | (2.5% x capital)/yr <sup>b</sup> , where Figure 7 shows capital investment  |
| Hauling of Waste to Temporary Storage (if required)                         | Figure 15 <sup>a</sup> plus Figure 12   |
| Waste Disposal (annual cost, knowing average tons per hour throughout year) | 10 miles from base <sup>a</sup> :<br>\$135,000 (TPH/2.8) <sup>0.6</sup> if TPH > 2.8; \$135,000 if TPH ≤ 2.8<br>50 miles from base <sup>a</sup> :<br>\$140,000 (TPH/2.2) <sup>0.75</sup> if TPH > 2.2; \$140,000 if TPH ≤ 2.2 |
| <b>B. Steam Turbine Cogeneration Plants, Oil- or Natural Gas-Fired</b>      |   |
| Steam Generating Facility   | \$1.10/10 <sup>3</sup> lb of steam <sup>c</sup> (for natural gas or distillate oil)<br>\$1.50/10 <sup>3</sup> lb of steam <sup>c</sup> (for residual oil)   |
| Electrical Generating Facility  | (2.5% x capital)/yr <sup>b</sup> , where Figure 7 shows capital investment  |
| Air Pollution Control System (only if designed to use high sulfur fuel)     | Figure 14 <sup>a</sup>  |
| <b>C. Combustion Turbine/Generator Sets With Exhaust Heat Boilers</b>       |   |
| Turbine/Generator Set   | 4.0 mils/kW-hr <sup>d</sup> for units operating on "continuous" duty, and for units ≤ 2 MWe on peaking duty<br>7.0 mils/kW-hr <sup>e</sup> for units > 2 MWe on peaking duty <sup>f</sup>                                     |
| Exhaust Heat Boiler   | \$1.00/10 <sup>3</sup> lb of steam  |

continued

Table 1. Continued

| Potential Contributor to O&M Costs                | Estimating Procedure or Figure  |
|---|---|
| D. Diesel/Generator Sets With Exhaust Heat Boiler |   |
| Diesel/Generator Set<br>Exhaust Heat Boiler       | 13 mils/kW-hr <sup>g</sup><br>\$1.00/10 <sup>3</sup> lb of steam <sup>f</sup> |

NOTE: For conventional steam generating facilities, use the appropriate parts of lists A and B above.

<sup>a</sup>Reference 2.

<sup>b</sup>Reference 1.

<sup>c</sup>Based on data from Long Beach Naval Shipyard and Sewell's Point Naval Complex compiled by CEL.

<sup>d</sup>Based on correspondence with Garrett Airesearch and Pacific Gas and Electric personnel. Includes costs for major overhauls.

<sup>e</sup>Based on data from San Diego Gas and Electric.

<sup>f</sup>CEL estimate.

<sup>g</sup>Based on Reference 3.

The fuel cost contribution to generated power is

$$FPC = (HR_{EFF})(CF)(1/10^3)$$

where FPC = fuel contribution to power costs, mils/kW-hr

CF = cost of fuel, \$/million Btu

For power from the cogeneration system to be economically attractive to the Navy, the fuel cost contribution must be sufficiently less than the cost of purchased power to allow for capital recovery and O&M. For the power to be economically attractive to a utility company, the fuel cost contribution must compare favorably with costs they experience or anticipate in their system.

## PERFORMANCE CURVES AND CHARACTERISTICS OF COGENERATION PLANTS

Table 2 compares characteristics of diesel, combustion turbine, and steam turbine types of cogeneration systems for which components and equipment are readily available commercially. Because the combined cycle system is basically a combination of a combustion turbine and a steam turbine, its characteristics can be inferred from the information presented. The table indicates that steam turbine systems have a distinct advantage in fuel flexibility and potential for multifuel capability. The choice of fuels has a most significant impact on the economics of cogeneration and the compliance of the system with environmental and energy regulations. Diesel and combustion turbine systems are typically limited to the use of premium fuels, petroleum or natural gas. There are exceptions; for example, some engines (not necessarily operating in the cogeneration mode) have been set up to burn waste gases or synthetic fuels, such as sewer gas, where a nearby cost-effective source exists. A limited number of installations have burned residual petroleum, but special facilities to "wash" the fuel, heat it, and inject additives were usually required. But typically, the diesel and combustion turbines require premium fuels. Table 2 provides guidance, in the form of "Typical Applications," for the use of the various types of systems.

Figure 17, based upon data in Reference 4, generalizes the performance of diesel cycle engines and presents the data in normalized form. The figure shows that just under one-third of the fuel energy is converted into shaft energy to drive the electrical generator (the shaft energy curve is the engine efficiency,  $\eta$ ); roughly one-third converts to heat, which is carried out in the exhaust gas; approximately 30% converts to heat, which is transferred to the jacket water and lubricating oil plus to airflow in the turbocharger (if the engine has a turbocharger); and about 5-10% is irretrievably lost from the engine structure. Practically all of the heat in the oil cooler, turbocharger aftercooler, and jacket water can be recovered as hot water or even low

pressure ( $\leq 15$  psig) steam. A temperature limit is set by the requirement to keep jacket water below 250°F on most engines. Figure 17 also shows the portion of the fuel energy recoverable from the exhaust gas stream at different temperatures. The normalized curves can be dimensionalized by assuming a full-load generator output,  $\dot{E}_{100}$  (kW). At any fraction of the full load output, the fuel energy input is

$$\dot{F} \left( \frac{\text{Btu}}{\text{hr}} \right) = \frac{\dot{E}}{\dot{E}_{100}} \left( \frac{\dot{E}_{100}}{\eta} \right) \left( \frac{3,413 \text{ Btu}}{\text{kW-hr}} \right)$$

Other quantities ratio according to the data from Figure 17.

Figure 18, also based upon data in Reference 4, is a similarly normalized performance curve for combustion turbines. Combustion turbines have no cooling jacket, and heat recovery potential from the lubricants is insignificant. Therefore, heat is only recoverable from the exhaust. It is seen that a significant portion of the fuel energy can be recovered to generate steam at 100 psig or higher, which is suitable for distribution over relatively long distances. The curves of Figure 18 are representative of many single-shaft, simple-cycle combustion turbines. Better part-load efficiencies are obtained with dual-shaft engines. Efficiency improvements may also be anticipated from future designs incorporating higher turbine inlet temperatures and recuperative heat exchangers.

Steam turbines do not lend themselves to a "universal" normalized curve of engine performance as the diesels and combustion turbines do. There are too many variables possible with steam turbine systems. Instead, a performance "map" of throttle steam flow rate versus electrical output, with extraction steam flow rate as a parameter, is illustrated in Figure 19. The specific generator design output throttle pressure, extraction pressure, and condenser pressure for which the curve is applicable are shown in Figure 19. The map is bounded by five essentially straight lines explained in the figure. It is noted that



the "map" does not extend down to  $\dot{E} = 0$ . The curves become non-linear at the low end of the scale, so it is better to design the equipment for operation at half-load or better in order to accurately map the performance. More detailed descriptions may be found in References 2 and 5.

An expression that relatively accurately relates the throttle flow rate to the electrical generation and the extraction flow rate is

$$\dot{M}_{THR} = \left[ \frac{\dot{E} - \frac{\dot{E}_B}{2}}{\frac{\dot{E}_B}{2}} \right] (\dot{M}_{THR,B} - \dot{M}_{THR,\frac{1}{2}B}) + \dot{M}_{THR,\frac{1}{2}B} + \dot{M}_{EXT} \left[ 1 - \frac{C(H_{THR} - H'_{EXT})}{(H_{THR} - H'_{EXH})} \right]$$

where  $\dot{M}_{THR}$  = throttle flow rate, lb/hr

$\dot{M}_{THR,B}$  = throttle flow rate at point B

$\dot{M}_{THR,\frac{1}{2}B}$  = throttle flow rate at  $\dot{E} = \frac{1}{2} \dot{E}_B$

$\dot{E}$  = electrical generation, kW

$\dot{E}_B$  = electrical generation at point B

$\dot{M}_{EXT}$  = extraction flow rate, lb/hr

$H_{THR}$  = enthalpy of steam at throttle valve, Btu/lb

$H'_{EXT}$  = enthalpy of steam at extraction valve, isentropic

$H'_{EXH}$  = enthalpy of steam leaving last turbine stage, isentropic

$C$  = dimensionless empirical factor,

0.857 when exhaust pressure  $\leq 1$  atm

0.902 when exhaust pressure  $\geq 1$  atm

For the special case of a backpressure turbine with no extraction,  $\dot{M}_{EXT} = 0$ , and  $\dot{M}_{THR}$  becomes a single-line function of  $\dot{E}$ .

Table 2. Characteristics of Cogeneration Systems

| Item                    | Diesel  | Combustion Turbine  | Steam Turbine  |
|-------------------------|---|---|--|
| Heat recovery source    | (1) Exhaust gas.<br>(2) Jacket water, plus oil cooler and turbo-charger cooler (if equipped with turbo-charger).  | Exhaust gas.  | Steam extraction between intermediate turbine stages (extraction turbine) or after final stage (backpressure turbine).   |
| State of recovered heat | (1) Through heat exchangers, exhaust provides hot water or saturated steam, usually $\leq 350^{\circ}\text{F}$ .<br>(2) Jacket water can provide hot water at $< 250^{\circ}\text{F}$ or saturated steam at $\leq 15$ psig.<br>(3) Exhaust can heat organic fluid through heat exchanger. | (1) Exhaust gas may be used directly for thermal content and $\text{O}_2$ content.<br>(2) Through heat exchanger, exhaust provides hot water or steam. Steam is usually saturated at pressures 10-200 psig. Possible to produce limited superheated steam up to $\approx 600^{\circ}\text{F}$ .<br>(3) Exhaust can heat organic fluid through heat exchanger. | Extracted or back-pressure steam is usually at a slightly superheated state. Boiler/turbine combinations can be selected to provide steam at desired pressures from atmosphere to 600+ psig, although pressures $\leq 200$ psig are most common. |
| Fuels                   | (1) Distillate petroleum.<br>(2) Natural gas.   | (1) Distillate petroleum.<br>(2) Natural gas.   | (1) Coal.<br>(2) Residual petroleum.<br>(3) Distillate petroleum.<br>(4) Natural gas.<br>(5) Biomass.<br>(6) Solid waste.<br>(7) Liquid or gaseous waste.  |

continued

Table 2. Continued

| Item                 | Diesel   | Combustion Turbine  | Steam Turbine   |
|----------------------|--|---|---|
| Capacity of units    | Almost continuous sizes up to 2 MWe. Frequent sizes to 4 MWe. Discrete sizes even larger.  | Limited choices available. Units available at nominal ratings of 0.5, 0.75, 2.5, 4.75, 6.8, 7.5, 10.0, 19.4, 24.7, 28.3, and larger discrete sizes.   | Standard NEMA ratings are 500, 700, 1,000, 1,500, 2,000, 2,500, 3,000, 4,000, 5,000, 6,000, and 7,500 kW. AIEE-ASME Preferred Standard Large 3,600-rpm, 3-phase, 60-cycle condensing unit ratings are 11.5, 15, 20, 30, 40, and 60 MWe. |
| Typical applications | Where the thermal load:<br>(1) Only requires hot water or low pressure steam;<br>(2) Is near the system;<br>(3) Is roughly equal to the electrical load. | Where the thermal load:<br>(1) Requires hot water or moderate (up to 200 psig) steam;<br>(2) May be remotely located, requiring thermal distribution;<br>(3) Is generally 1 to 3 times the electrical load. | Where the thermal load:<br>(1) Is the essential load which would require reliable boilers anyway;<br>(2) Is generally large.  |

The fuel energy required for a steam turbine system is

$$\dot{F}(\text{Btu/hr}) = \frac{\dot{M}_{\text{THR}}(H_{\text{THR}} - H_{\text{FW}})}{\eta_{\text{BLR}}}$$

where  $H_{\text{FW}}$  = enthalpy of feedwater (mixed makeup plus condensate return) entering water treatment, Btu/lb

$\eta_{\text{BLR}}$  = overall boiler efficiency, dimensionless

## ENERGY/ENVIRONMENTAL LEGISLATION AND REGULATIONS

Legislation and regulations are subject to changes and revisions. It will be necessary, therefore, to verify compliance of the cogeneration system design with appropriate legislation and regulations in effect at the time and in the specific location. The energy and environmental mandates in effect or recommended as of 1979, summarized from Reference 6, provide some insight into the types of legislative/regulatory matters which are likely to apply to cogeneration, now or in the future.

The Powerplant Industrial Fuel Use Act provides that new powerplants or fuel-burning installations of a single unit having a design fuel heat input of  $100 \times 10^6$  Btu/hr or greater, or which result in two or more units at the same site having a combined design fuel heat input rate of  $250 \times 10^6$  Btu/hr or greater, are prohibited from burning natural gas or petroleum, unless an exemption is provided by the Secretary of Energy. However, the Secretary of Energy is specifically authorized to exempt cogeneration facilities from the prohibition if the benefits of cogeneration are otherwise unobtainable. (Guidelines for exemption have been formulated.)

As points of reference,  $100 \times 10^6$  Btu/hr corresponds roughly to a 7,500-kWe combustion turbine or a 4,500-kWe steam turbine system. It is seen that rather small installations, which would be more likely to involve natural gas- or petroleum-fired diesels or combustion turbines, are not restricted in choice of fuels under the Fuel Use Act.

The Public Utility Regulatory Policies Act of 1978 directs the Federal Energy Regulatory Commission (FERC) of the Department of Energy to develop regulations for encouraging cogeneration and small power production facilities using biomass, waste materials, renewable resources, or any combination of these as the primary energy source. The adjective "small" means that the power production capacity, together with any other facilities located at the same site, is not to be greater than 80 MWe. The regulations developed by FERC must include provisions to ensure that utilities buy or sell power from these types of facilities at equitable prices. Fossil fuels (coal, petroleum, and natural gas) are not considered renewable resources. As of March 1980, however, FERC has ruled that if cogeneration facilities under 30 MWe want to sell excess electricity to a utility, the utility must buy it at rates comparable to the utility's power-producing rates and provide warning to the cogenerator if the cogenerator would lose money at that rate. Utilities will be required to provide backup power and transmission equipment.

The Clean Air Act of 1977 requires that each state submit documentation to EPA of the attainment status of its air quality control regions for each of six pollutants for which national ambient air quality standards have been set. Areas with air quality better than the standards would be designated as an area of Prevention of Significant Deterioration (PSD), while an area where the air quality does not meet the standards would be termed a nonattainment area (NA). EPA has proposed new-source performance standards for new or modified steam-electric units capable of combusting more than  $250 \times 10^6$  Btu/hr of fossil fuel. Performance standards for new sources would apply to modified or reconstructed facilities also, where the cost is 50% or more of the cost of replacing the existing powerplant. Another provision is that addition of pollutants to the atmosphere from new sources in NA regions must be more than offset by the further removal of pollutants from nearby existing sources by means of shutdowns, process changes, or additional pollution abatement equipment. All existing facilities owned by the company commissioning the new plant must be in compliance with applicable emission limits and standards.

Under the Resource Conservation and Recovery Act, EPA is empowered to identify and regulate hazardous wastes. Currently, powerplant wastes (flyash, bottom ash, scrubber sludge) are called "special wastes" and "problem wastes," and as such can be disposed of in sanitary landfills rather than in hazardous waste facilities. The characteristics of solid wastes from power plants are still being examined, however.

Discharges of heavy metals and toxic pollutants are controlled under the Clean Water Act. A powerplant must have a national pollutant discharge elimination system (NPDES) permit to discharge treated wastewater directly into a navigable waterway, and discharges to municipal sewers usually have to be in compliance with some wastewater quality guidelines established by the local sewage treatment agency. Potential impact of the Clean Water Act may be future regulations for: (a) a tank or cover over coal piles to prevent rainwater from picking up pollutants from the coal and flowing into streams, lakes, or sewers; (b) containment dikes to prevent coal-pile runoff; (c) ash pond linings to prevent seepage of pollutants into the ground water; and (d) prescribed or controlled cooling tower biocide-treatment practices to reduce toxic substances.

EPA has proposed emission standards for stationary engine/generator sets, including rather small units used in cogenerating facilities. Separate standards are proposed for combustion turbines and diesels.  $\text{NO}_x$  reduction is a primary goal of the standards. For combustion turbines, water injection during the combustion process appears to be the means of achieving the standards. It is basically the responsibility of new engine manufacturers to design their products to comply with new standards. Some future modifications of existing non-compliant engines may be required if they are used in a cogeneration system.

In addition to the federal legislation described above, each state maintains its jurisdiction over utility services through a Public Utilities Commission (PUC), or comparable body. A PUC may establish regulations or issue rulings affecting potential cogeneration applications. States may also have special tax incentives or other legislation favorable

to cogeneration, of which the PUC would be aware. Since specifics differ from one state to another, the cognizant PUC would have to be contacted for relevant information regarding state legislation and products of its own authority regarding cogeneration in general, or for comments on a specific application of cogeneration.

## INSTITUTIONAL CONSTRAINTS

Human preferences and opinions can have a strong influence on the consideration being given to cogeneration system alternatives. Those factors that are not solidly supported on technical or economic grounds, or mandated by legislation or regulations, are termed "institutional" factors. Some examples which often have to be dealt with in order to implement cogeneration are listed below.

- Corporate resistance due to concern that plant will become regulated by PUC
- Restrictive utility company policies on standby charges or ownership/operation options in order to obtain connection to the grid
- Corporate policy "not to get into the utility business"
- Unavailability of skilled personnel to operate new facility
- Reluctance by operating and maintenance personnel to assume new duties and responsibilities
- Concern over job losses if system is operated by utility company
- Community resistance to placement of the generating facility

Institutional factors are often very difficult to deal with. They are not generally quantifiable. Their root cause is often difficult or impossible to determine. They may even be contradictory. The best

approach appears to be to express the nature of the institutional barriers in the clearest possible terms when they are encountered. Clear definition of a barrier is necessary for open examination, which is a big step toward solution.

## IMPLEMENTING COGENERATION

The preceding discussions have pointed out that implementation of cogeneration can be a complex process involving technical, economic/financial, legislative/regulatory, and institutional factors. Guidance relevant to these factors has been outlined, and the need for a great deal of information has been discussed. This final section will describe a likely sequence of tasks leading from the seeds of thought regarding cogeneration to its implementation. Also in this final section, likely sources for much of the required information will be listed.

First, look at typical tasks involved in proceeding from concept to hardware. For a particular site, of course, circumstances may preclude some of the steps from occurring, or change the order, or even extend the process. However, these are basically the steps to be expected.

1. Question whether the existing thermal and electrical utility service is best for the facility, and whether cogeneration holds potential for achieving energy or cost savings. If changes such as an expansion or conversion to a different fuel are planned anyway, the consideration of incorporating cogeneration is often in order.

2. Conduct an energy audit or survey. Gather and analyze information on existing and anticipated loads, costs, and alternatives for conservation.

3. Formulate concepts of utility system alternatives. At this point, an approach somewhat like brainstorming is beneficial. Be open to various cogeneration options, including different types of equipment, capacities, and ownership/operation arrangements.



4. Determine constraints applicable to the various options and eliminate infeasible concepts from consideration. This is really a critical step. It is easy to eliminate a feasible approach by perceiving something as a constraint that really is not. For example, it is easy to rationalize that no utility company would be interested in participating in the cogeneration project under consideration. By exploratory discussions, however, it may be learned otherwise. Make sure that constraints used to eliminate various approaches are well founded, and be open to reconsidering the constraints and their impact later if conditions change.

5. Perform elementary performance estimates, environmental assessments, and cost estimates on promising alternatives, resulting in a preliminary ranking.

6. Discuss acceptance of alternatives with management, utility companies, permitting agencies, fuel suppliers, and other potentially involved parties. From discussions, define items requiring negotiation and further clarification.

7. Reassess the alternatives and rankings, as necessary.

8. For the preferred alternatives, identify any contractual arrangements that are critical to the success of the alternative. Conduct discussions with involved parties, arriving at "Agreements in Principle" on the critical items.

9. Select alternative for design. Proceed with design to an intermediate design review point. Formulate Environmental Impact Statement (EIS), if necessary.

10. Review intermediate design. Submit EIS and permit requests.

11. Complete contract negotiations with involved parties.

12. Complete plant design.

13. Proceed into construction of plant.

Potential involved parties and sources of information for various aspects of cogeneration are indicated in Table 3. In many cases there is more than one source for particular pieces of information or data.

Quite often the talents and insight of consultants/designers who are experienced or specialize in the cogeneration field are necessary in order to effectively address factors arising in deciding upon, designing, and successfully deploying a system. Assistance in recognizing and dealing with the tradeoffs between technical performance, economics, and obstacles to implementation can be most beneficial. The interest in cogeneration by numerous industrial firms, commercial concerns, and institutions as a means of achieving energy and cost savings, the encouragement offered by federal agencies and some states, and the growing acceptance by utility companies are all helpful in removing the obstacles to cogeneration.

#### REFERENCES

1. Department of Energy, Office of Industrial Programs. Report No. HCP/M 8688-01: Guidelines for developing state cogeneration policies, April 1979. Resource Planning Associates, Apr 1979. (Contract No. EC-77-01-8688)
2. Civil Engineering Laboratory. Contract Report CR 79.012: Coal-fired boilers at Navy bases, Navy energy guidance study phases II and III. Bechtel National, Inc., May 1979. (Contract No. N68305-77-C-0003)
3. Bulletin 3382270 and other information from the Cummins Cogeneration Company, Suite 1134 Empire State Bldg, New York, N.Y.
4. Civil Engineering Laboratory. Report No. BA 9005-454: Procedures for feasibility analysis and preliminary design of total energy systems at military facilities. Booz-Allen and Hamilton. (Contract No. N62399-73-C-0029)

5. J. Kenneth Salisbury, editor. Kent's mechanical engineer's handbook, power volume, section 8, 12th ed. New York, N.Y., Wiley Handbook Series.

6. 1979 Generation Planbook, by the editors of POWER Magazine. New York, N.Y., McGraw-Hill, pp 165-183.

7. U.S. Department of Energy. The potential for cogeneration development in six major industries by 1985, by Resource Planning Associates, Inc., Dec 1977.

Table 3. Sources of Information for Decision on Cogeneration

| Required Information   | Source of Information |                 |                             |                     |            |                           |                      |  |                                  |                        |
|--|-----------------------|-----------------|-----------------------------|---------------------|------------|---------------------------|----------------------|--|----------------------------------|------------------------|
|  | Energy Audit          | Utility Company | Fuel Suppliers <sup>a</sup> | Equipment Suppliers | Management | Public Utility Commission | Air Quality District | Sanitation and Water Quality Districts | Special Authorities <sup>b</sup> | Financial Institutions |
| Total Thermal Loads, Magnitude and Profile<br>Total Electrical Loads, Magnitude and Profile<br>Cooling Loads<br>Major Load Centers and Energy Consumers<br>Anticipated Load Changes, Mission or Function Changes<br>Waste Heat Sources<br>Waste Fuel Sources<br>Complementary Off-Site Loads<br>Present Electrical Energy Costs and Rate Formats<br>Projected Electrical Energy Rate Structure                                       | X                     |                 |                             |                     |            |                           |                      |  |                                  |                        |
|  | X                     |                 |                             |                     |            |                           |                      |  |                                  |                        |
|  | X                     |                 |                             |                     |            |                           |                      |  |                                  |                        |
|  | X                     |                 |                             |                     |            |                           |                      |  |                                  |                        |
|  | X                     |                 |                             |                     |            |                           |                      |  |                                  |                        |
|  | X                     |                 |                             |                     |            |                           |                      |  |                                  |                        |
|  | X                     |                 |                             |                     |            |                           |                      |  |                                  |                        |
|  | X                     |                 |                             |                     |            |                           |                      |  |                                  |                        |
|  | X                     |                 |                             |                     |            |                           |                      |  |                                  |                        |
|  | X                     |                 |                             |                     |            |                           |                      |  |                                  |                        |
| Policies Toward Parallel Generation<br>Ownership/Operation Policies and Preferences<br>Cogenerator Rate Structure: Standby Charges, Reliability Requirements, Payment for Power to Grid<br>Environmental and Siting Constraint Overview<br>Tax and Investment Incentives<br>Regulations Relative to Cogeneration<br>Present Fuel Costs<br>Projected Fuel Costs<br>Projected Fuel Availability<br>Fuel Characteristics and Properties |                       | X               |                             |                     | X          |                           |                      |  |                                  |                        |
|  |                       | X               |                             |                     |            |                           |                      |  |                                  |                        |
|  |                       | X               | X                           |                     |            |                           |                      |  |                                  |                        |
|  |                       | X               | X                           |                     |            |                           |                      |  |                                  |                        |
|  |                       | X               | X                           |                     |            |                           |                      |  |                                  |                        |
|  |                       | X               | X                           |                     |            |                           |                      |  |                                  |                        |
|  |                       | X               |                             |                     |            | X                         |                      |  |                                  |                        |
|  |                       | X               |                             |                     |            |                           |                      |  |                                  |                        |
|  |                       | X               |                             |                     |            |                           |                      |  |                                  |                        |
|  |                       | X               |                             |                     |            |                           |                      |  |                                  |                        |
| Performance Data: Design and Off Design Conditions<br>Fuel Consumption<br>Fuel Flexibility<br>Emissions Data and Specifications<br>Air Emissions Regulations<br>Other Emissions Regulations<br>Fiscal Policies<br>Funding Sources<br>Cost and Conditions of Financing<br>Siting Restrictions   |                       |                 |                             | X                   |            |                           |                      |  |                                  |                        |
|  |                       |                 |                             | X                   |            |                           |                      |  |                                  |                        |
|  |                       |                 |                             | X                   |            |                           |                      |  |                                  |                        |
|  |                       |                 |                             | X                   |            |                           |                      |  |                                  |                        |
|  |                       |                 |                             | X                   |            |                           | X                    |  |                                  |                        |
|  |                       |                 |                             | X                   |            |                           |                      | X                                      |                                  |                        |
|  |                       |                 |                             | X                   |            |                           |                      |  |                                  |                        |
|  |                       |                 |                             |                     | X          |                           |                      |  |                                  |                        |
|  |                       |                 |                             |                     | X          |                           |                      |  |                                  |                        |
|  |                       |                 |                             |                     |            |                           |                      |  |                                  |                        |

<sup>a</sup> Oil, natural gas, or coal.<sup>b</sup> For example, zoning, airport, coastal.

Example: Need 200 units of energy as steam  
100 units of energy as electricity




Figure 1. Energy balance comparison.




Figure 2. Thermal/electrical capabilities of cogeneration systems.




Figure 3. Examples of cogeneration concept.




Figure 4. Integrated utility company service and cogeneration plant.






Figure 5. Steam generator costs.




Figure 6. Air emission control system costs.




Figure 7. Steam turbine generator costs.




Figure 8. Coal- and waste-handling facility costs.





Figure 9. Diesel and combustion turbine system costs.



- 1 Twelve month delivery schedule for steam generators rated at 3 million pounds per hour and under only
- 2 Work phase completed for steam generators rated at 300,000 pounds per hour and under only
- 3 Work phase completed for steam generators rated at 1 million pounds per hour and under only
- 4 Work phase completed for all steam generators rated over 1 million pounds per hour

Figure 10. Estimated implementation schedules for cogeneration plants and process steam boilers (Ref 7).




Figure 11. Operating and maintenance costs for central receiving and coal-handling facilities with stockpile.




Figure 12. Operating and maintenance costs for short distance hauling of coal or solid waste.






Figure 13. Operating and maintenance costs for coal-fired steam boilers.




Figure 14. Operating and maintenance costs for air pollution control of coal-fired generating plants.




Figure 15. Solid waste production as a function of ash and sulfur content in coal.




Figure 16. Fuel cost contribution to power costs for cogeneration systems.




Figure 17. Heat balance for diesel engine in heat recovery application, relative output.




Figure 18. Heat balance for combustion turbine in heat recovery application, relative output.




Figure 19. Performance map for an extraction/condensing steam turbine-generator set.

## DISTRIBUTION LIST

AAP NAVORDSTA IND HD DET PW ENGRNG DIV, McAlester, OK  
 AF HQ AFLEY Washington, DC  
 AFB (AFIT LD), Wright-Patterson OH; ABG DEE (F. Netters), Goodfellow AFB TX; AERO Propulsion Lab  
 (Energy Conv) Wright Patterson OH; AF Tech Office (Mgt & Ops), Tyndall, FL; AFCEC/XR, Tyndall FL;  
 CESCII, Wright-Patterson; MAC DET (Col. P. Thompson) Scott, IL; SAMSO MNND, Norton AFB CA;  
 Samso, Vandenburg, AFB, CA; Stinfo Library, Offutt NE  
 ARMY (SAIL-FM) OSA Washington, DC; BMDSC-RE (H. McClellan) Huntsville AL; DAEN-CWE-M (L. C  
 D Binning), Washington DC; DAEN-FEU-E (J. Ronan), Washington DC; DAEN-MPE-D Washington DC;  
 DAEN-MPR Washington, DC; DAEN-MPL, Washington DC; ERADCOM Tech Supp Dir. (DELS-D-L) Ft.  
 Monmouth, NJ; FESA-TS Fort Belvoir VA; Natick Cen (Kwoh Hu) Natick MA; Tech. Ref. Div., Fort  
 Huachuca, AZ  
 ARMY - CERL Energy & Habitability Div Champaign IL; Library, Champaign IL  
 ARMY CORPS OF ENGINEERS MRD-Eng. Div., Omaha NE; Seattle Dist. Library, Seattle WA  
 ARMY CRREL G. Phetteplace Hanover, NH  
 ARMY DARCOM AMCPM-CS (J. Carr), Alexandria VA  
 ARMY ENG WATERWAYS EXP STA Library, Vicksburg MS  
 ARMY ENGR DIST. Library, Portland OR  
 ARMY MATERIALS & MECHANICS RESEARCH CENTER Dr. Lenoe, Watertown MA  
 ARMY MISSILE R&D CMD Redstone Arsenal AL Sci. Info. Cen (Documents)  
 ASO PWD (ENS J.A. Jenkins), Philadelphia, PA  
 ASST SECRETARY OF THE NAVY Spec. Assist Energy (Leonard), Washington, DC  
 BUREAU OF RECLAMATION Code 1512 (C. Selander) Denver CO  
 CINCLANT Civil Engr. Supp. Plans. Ofc Norfolk, VA  
 CNAVRES Code 13 (Dir. Facilities) New Orleans, LA  
 CNET SCE Pensacola, FL  
 CNM Code MAT-08T3, Washington, DC  
 CNO Code NOP-964, Washington DC; Code OP 323, Washington DC; Code OP 987 Washington DC; Code  
 OP-413 Wash, DC; Code OPNAV 09B24 (H); OP987J (J. Boosman), Pentagon  
 COMFLEACT, OKINAWA PWO, Kadena, Okinawa  
 COMNAV MARIANAS Code N4, Guam  
 COMOCEANSYSPAC SCE, Pearl Harbor HI  
 COMSUBDEVGRUONE Operations Ofc, San Diego, CA  
 DOE F.F. Parry, Washington DC; INEL Tech. Lib. (Reports Section), Idaho Falls, ID; Liffick, Richmond,  
 WA; P. Jordan Washington, DC  
 DTNSRDC Code 4111 (R. Gierich), Bethesda MD  
 DINSRDC Code 522 (Library), Annapolis MD  
 ENVIRONMENTAL PROTECTION AGENCY Reg. VIII, 8M-ASL, Denver CO  
 FLTCOMBATTRACENLANT PWO, Virginia Bch VA  
 GSA Office of Const. Mgmt (M. Whitley), Washington DC  
 KWAJALEIN MISRAN BMDSC-RKL-C  
 MARINE CORPS BASE Camp Pendleton CA 92055; Code 43-260, Camp Lejeune NC; PWO Camp Lejeune  
 NC; PWO, Camp S. D. Butler, Kawasaki Japan  
 MARINE CORPS HQS Code LFF-2, Washington DC  
 MCAS Facil. Engr. Div. Cherry Point NC; CO, Kaneohe Bay HI; Code S4, Quantico VA; PWO Kaneohe Bay  
 HI; PWO, Yuma AZ; SCE, Futema Japan  
 MCDEC NSAP REP, Quantico VA  
 MCLSBPAC B520, Barstow CA; PWO, Barstow CA  
 MCRD PWO, San Diego Ca  
 FT19 SCE San Diego, CA  
 NAF PWD - Engr Div, Atsugi, Japan; PWO Sigonella Sicily; PWO, Atsugi Japan  
 NALF OINC, San Diego, CA  
 NARF Code 100, Cherry Point, NC; Code 612, Jax, FL; Code 640, Pensacola FL  
 NAS CO, Guantanamo Bay Cuba; Code 114, Alameda CA; Code 183 (Fac. Plan BR MGR); Code 18700,  
 Brunswick ME; Code 18U (ENS P.J. Hickey), Corpus Christi TX; Code 6234 (G. Trask), Point Mugu CA;  
 Code 8E, Patuxent Riv., MD; Dir. Util. Div., Bermuda; ENS Buchholz, Pensacola, FL; Lakehurst, NJ;



Lead. Chief. Petty Offr. PW/Self Help Div. Beeville TX; PW (J. Maguire). Corpus Christi TX; PWD Maint.  
 Cont. Dir., Fallon NV; PWD Maint. Div., New Orleans, Belle Chasse LA; PWD, Maintenance Control  
 Dir., Bermuda; PWD, Willow Grove PA; PWO Belle Chasse, LA; PWO Chase Field Beeville, TX; PWO  
 Key West FL; PWO Whiting Fld, Milton FL; PWO, Dallas TX; PWO, Glenview IL; PWO, Millington TN;  
 PWO, Miramar, San Diego CA; SCE Lant Fleet Norfolk, VA; SCE Norfolk, VA; SCE, Barbers Point HI  
 NATL RESEARCH COUNCIL Naval Studies Board, Washington DC  
 NAVACT PWO, London UK  
 NAVAEROSPREGMEDCEN SCE, Pensacola FL  
 NAVCOASTSYSTCTR CO, Panama City FL; Code 713 (J. Quirk) Panama City, FL; Library Panama City, FL  
 NAVCOMMAREAMSTRSTA PWO, Norfolk VA; PWO, Wahiawa HI; SCE Unit 1 Naples Italy  
 NAVCOMMSTA CO (61E) Puerto Rico; Code 401 Nea Makri, Greece; PWO, Exmouth, Australia; PWO, Fort  
 Amador Canal Zone; SCE Keflavik, Iceland; SCE Rota Spain  
 NAVEDTRAPRODEVEN Tech. Library  
 NAVEDUTRACEN Engr Dept (Code 42) Newport, RI  
 NAVEOFAC Code 605, Indian Head MD  
 NAVFAC PWO Eleuthera BF; PWO, Cape Hatteras, Buxton NC; PWO, Centerville Bch, Ferndale CA; PWO,  
 Guam  
 NAVFAC PWO, Lewes DE  
 NAVFACENGCOM Code 043 Alexandria, VA; Code 044 Alexandria, VA; Code 0451 Alexandria, VA; Code  
 0454B Alexandria, VA; Code 04B5 Alexandria, VA; Code 081B Alexandria, VA; Code 100 Alexandria, VA;  
 Code 1113 (M. Carr) Alexandria, VA; Code 1113 (T. Stevens) Alexandria, VA; Morrison Yap, Caroline Is.  
 NAVFACENGCOM - CHES DIV. Code 102, (Wildman), Wash, DC; Code 403 (H. DeVoe) Wash, DC; Code  
 FPO-1 Wash, DC  
 NAVFACENGCOM - LANT DIV. CDR E. Peltier; Code 111, Norfolk, VA; European Branch, New York;  
 RDT&ELO 102, Norfolk VA  
 NAVFACENGCOM - NORTH DIV. AROICC, Brooklyn NY; Code 09P (LCDR A.J. Stewart); Code 1028,  
 RDT&ELO, Philadelphia PA; Code 111 (Castranovo) Philadelphia, PA; Code 114 (A. Rhoads); Design  
 Div. (R. Masino), Philadelphia PA; ROICC, Contracts, Crane IN  
 NAVFACENGCOM - PAC DIV. (Kyi) Code 101, Pearl Harbor, HI; Code 402, RDT&E, Pearl Harbor HI;  
 Commander, Pearl Harbor, HI  
 NAVFACENGCOM - SOUTH DIV. Code 90, RDT&ELO, Charleston SC  
 NAVFACENGCOM - WEST DIV. 112; AROICC, Contracts, Twentynine Palms CA; Code 04B San Bruno,  
 CA; 09P/20 San Bruno, CA; RDT&ELO Code 2011 San Bruno, CA  
 NAVFACENGCOM CONTRACT AROICC, Quantico, VA; Code 09E, TRIDENT, Bremerton WA; Dir. Eng.  
 Div., Exmouth, Australia; Eng Div dir, Southwest Pac, Manila, PI; OICC (Knowlton), Kaneohe, HI; OICC,  
 Southwest Pac, Manila, PI; OICC/ROICC, Balboa Canal Zone; ROICC AF Guam; ROICC, Keflavik,  
 Iceland; ROICC, Pacific, San Bruno CA  
 NAVNUPWRU MUSE DET Code NPU-30 Port Hueneme, CA  
 NAVOCEANO Code 1600 Bay St. Louis, MS  
 NAVOCEANSYSCEN Code 41, San Diego, CA; Code 523 (Hurley), San Diego, CA; Code 5311 San Diego,  
 CA; Code 6700, San Diego, CA; Code 811 San Diego, CA; Research Lib., San Diego CA; Tech. Library,  
 Code 447  
 NAVORDSTA PWO, Louisville KY  
 NAVPETOFF Code 30, Alexandria VA  
 NAVPETRES Director, Washington DC  
 NAVPHIBASE CO, ACB 2 Norfolk, VA; Code S3T, Norfolk VA  
 NAVREGMEDCEN PWO Okinawa; SCE San Diego, CA; SCE Yokosuka JA; SCE, Camp Pendleton CA; SCE,  
 Guam; SCE, Oakland CA  
 NAVSCOLCECOFF C35 Port Hueneme, CA  
 NAVSEASYSOM Code 0325, Program Mgr, Washington, DC; Code OOC (LT R. MacDougal), Washington  
 DC; Code SEA OOC Washington, DC  
 NAVSEC Code 6034 (Library), Washington DC  
 NAVSECGRUACT PWO, Adak AK; PWO, Edzell Scotland; PWO, Puerto Rico; PWO, Torri Sta, Okinawa  
 NAVSHIPYD Code 202.4, Long Beach CA; Code 202.5 (Library) Puget Sound, Bremerton WA; Code 380,  
 (Woodroff) Norfolk, Portsmouth, VA; Code 400, Puget Sound; Code 400.03 Long Beach, CA; Code 404  
 (LT J. Riccio), Norfolk, Portsmouth VA; Code 410, Mare Is., Vallejo CA; Code 440 Portsmouth NH; Code  
 440, Norfolk; Code 440, Puget Sound, Bremerton WA; Code 450, Charleston SC; Code 453 (Util. Supr),  
 Vallejo CA; L.D. Vivian, Library, Portsmouth NH; PWO, Mare Is.; PWO, Puget Sound; SCE, Pearl  
 Harbor HI

NAVSTA CO Naval Station, Mayport FL; Dir Mech Engr. Gtmo; Engr. Dir., Rota Spain; Long Beach, CA;  
 Maint. Cont. Div., Guantanamo Bay Cuba; Maint. Div. Dir/Code 531, Rodman Canal Zone; PWO Midway  
 Island; PWO, Keflavik Iceland; PWO, Mayport FL; ROICC, Rota Spain; SCE, Guam; SCE, San Diego CA;  
 SCE, Subic Bay, R.P.; Utilities Engr Off. (A.S. Ritchie), Rota Spain  
 NAVSUBASI ENS S. Dove, Groton, CT; PWO Bangor, Bremerton, WA  
 NAVSUPACT CO, Seattle WA; Code 4, 12 Marine Corps Dist, Treasure Is., San Francisco CA; Code 413,  
 Seattle WA; LTJG McGarrah, SEC, Vallejo, CA  
 NAVSURFWPNCEN PWO, White Oak, Silver Spring, MD  
 NAVTECHTRACEN SCE, Pensacola FL  
 NAVUSEAWARENGSTA Keyport, WA  
 NAVWPNCEN Code 2636 (W. Bonner), China Lake CA; PWO (Code 26), China Lake CA; ROICC (Code  
 702), China Lake CA  
 NAVWPNEVALFAC Technical Library, Albuquerque NM  
 NAVWPNSTA Code 092A (C. Fredericks) Seal Beach CA  
 NAVWPNSTA PW Office (Code 09C1) Yorktown, VA  
 NAVWPNSTA PWO, Seal Beach CA  
 NAVWPNSUPPCEN Code 09 Crane IN  
 NCBC Code 10 Davisville, RI; Code 155, Port Hueneme CA; Code 156, Port Hueneme, CA; Code 2511 Port  
 Hueneme, CA; NESO Code 251 P.R. Winter Port Hueneme, CA; PW Engrg, Gulfport MS; PWO (Code 80)  
 Port Hueneme, CA; PWO, Davisville RI  
 NMCB 5, Operations Dept., Forty, CO; THREE, Operations Off.  
 NOAA Library Rockville, MD  
 NRL Code 8400 Washington, DC; Code 8441 (R.A. Skop), Washington DC  
 NSC Code 54.1 (Wynne), Norfolk VA  
 NSD SCE, Subic Bay, R.P.  
 NTC Commander Orlando, FL  
 NUSC Code 131 New London, CT; Code EA123 (R.S. Munn), New London CT; Code SB 331 (Brown),  
 Newport RI; Code TA131 (G. De la Cruz), New London CT  
 OCEANSYSLANT LT A.R. Giancola, Norfolk VA  
 ONR BROFF, CO Boston MA; Code 221, Arlington VA; Code 481, Arlington VA; Code 700F Arlington VA;  
 Dr. A. Laufer, Pasadena CA  
 PACMISRANFAC CO, Kekaha HI  
 PHIBCB 1 P&E, Coronado, CA  
 PMTC Code 3331 (S. Opatowsky) Point Mugu, CA; Code 4253-3, Point Mugu, CA; Pat. Counsel, Point Mugu  
 CA  
 PWC (Lt E.S. Agonoy) Pensacola, FL; ACE Office (LTJG St. Germain) Norfolk VA; CO Norfolk, VA; CO,  
 (Code 10), Oakland, CA; CO, Great Lakes IL; Code 10, Great Lakes, IL; Code 110, Oakland, CA; Code  
 120, Oakland CA; Code 120C, (Library) San Diego, CA; Code 128, Guam; Code 154, Great Lakes, IL;  
 Code 200, Great Lakes IL; Code 220 Oakland, CA; Code 220.1, Norfolk VA; Code 30C, San Diego, CA;  
 Code 400, Great Lakes, IL; Code 400, Oakland, CA; Code 400, Pearl Harbor, HI; Code 400, San Diego,  
 CA; Code 420, Great Lakes, IL; Code 420, Oakland, CA; Code 42B (R. Pascua), Pearl Harbor HI; Code  
 505A (H. Wheeler); Code 600, Great Lakes, IL; Code 601, Oakland, CA; Code 610, San Diego Ca; Code  
 700, Great Lakes, IL; LTJG J.L. McClaine, Yokosuka, Japan; Utilities Officer, Guam; XO (Code 20)  
 Oakland, CA  
 TRIREFFAC SCE Bremerton, WA  
 TVA Smelser, Knoxville, Tenn.  
 U.S. MERCHANT MARINE ACADEMY Kings Point, NY (Reprint Custodian)  
 USAF Jack S. Spencer, Washington, DC  
 USAF REGIONAL HOSPITAL Fairchild AFB, WA  
 USCG (G-ECV) Washington Dc; (Smith), Washington, DC; G/E (TP-62) (RADM Thompson) Washington, DC  
 USCG R&D CENTER CO Groton, CT; D. Motherway, Groton CT; Tech. Dir. Groton, CT  
 USDA Forest Service, Bowers, Atlanta, GA; Forest Service, San Dimas, CA  
 USNA Ch. Mech. Engr. Dept Annapolis MD; Energy-Environ Study Grp, Annapolis, MD; Engr. Div. (C. Wu)  
 Annapolis MD; Environ. Prot. R&D Prog. (J. Williams), Annapolis MD; Ocean Sys. Eng Dept (Dr.  
 Monney) Annapolis, MD; Civil Engr Dept (R. Erchyl) Annapolis MD; PWD Engr. Div. (C. Bradford)  
 Annapolis MD  
 AMERICAN UNIVERSITY Washington DC (M. Norton)  
 ARIZONA State Energy Programs Off., Phoenix AZ

BONNEVILLE POWER ADMIN Portland OR (Energy Consv. Off., D. Davey)  
 BROOKHAVEN NATL LAB M. Steinberg, Upton NY  
 CALIFORNIA STATE UNIVERSITY LONG BEACH, CA (CHELAPATI)  
 CORNELL UNIVERSITY Ithaca NY (Serials Dept, Engr Lib.)  
 DAMES & MOORE LIBRARY LOS ANGELES, CA  
 FLORIDA TECHNOLOGICAL UNIVERSITY ORLANDO, FL (HARTMAN)  
 FOREST INST. FOR OCEAN & MOUNTAIN Carson City NV (Studies - Library)  
 FUEL & ENERGY OFFICE CHARLESTON, WV  
 GEORGIA INSTITUTE OF TECHNOLOGY (LT R. Johnson) Atlanta, GA  
 HAWAII STATE DEPT OF PLAN. & ECON DEV. Honolulu HI (Tech Info Ctr)  
 INDIANA ENERGY OFFICE Energy Group, Indianapolis, IN  
 KEENE STATE COLLEGE Keene NH (Cunningham)  
 LEHIGH UNIVERSITY BETHLEHEM, PA (MARINE GEOTECHNICAL LAB., RICHARDS); Bethlehem  
 PA (Linderman Lib, No.30, Flecksteiner)  
 LIBRARY OF CONGRESS WASHINGTON, DC (SCIENCES & TECH DIV)  
 LOUISIANA DIV NATURAL RESOURCES & ENERGY Dept. of Conservation, Baton Rouge LA  
 MAINE OFFICE OF ENERGY RESOURCES Augusta, ME  
 MISSOURI ENERGY AGENCY Jefferson City MO  
 MIT Cambridge MA (Rm 10-500, Tech. Reports, Engr. Lib.); Cambridge, MA (Harleman)  
 MONTANA ENERGY OFFICE Anderson, Helena, MT  
 NATL ACADEMY OF ENG. ALEXANDRIA, VA (SEARLE, JR.)  
 NEW HAMPSHIRE Concord, NH, (Governor's Council On Energy)  
 NEW MEXICO SOLAR ENERGY INST. Dr. Zwiibel Las Cruces NM  
 NY CITY COMMUNITY COLLEGE BROOKLYN, NY (LIBRARY)  
 NYS ENERGY OFFICE Library, Albany NY  
 PENNSYLVANIA STATE UNIVERSITY State College PA (Applied Rsch Lab)  
 POLLUTION ABATEMENT ASSOC. Graham  
 PURDUE UNIVERSITY Lafayette, IN (CE Engr. Lib)  
 CONNECTICUT Hartford CT (Dept of Plan. & Energy Policy)  
 SEATTLE U Prof Schwaegler Seattle WA  
 SOUTHWEST RSCH INST King, San Antonio, TX; R. DeHart, San Antonio TX  
 STANFORD UNIVERSITY Engr Lib, Stanford CA  
 STATE UNIV. OF NEW YORK Fort Schuyler, NY (Longobardi)  
 TEXAS A&M UNIVERSITY W.B. Ledbetter College Station, TX  
 UNIVERSITY OF CALIFORNIA Energy Engineer, Davis CA; LIVERMORE, CA (LAWRENCE  
 LIVERMORE LAB, TOKARZ); Vice President, Berkeley, CA  
 UNIVERSITY OF HAWAII HONOLULU, HI (SCIENCE AND TECH. DIV.)  
 UNIVERSITY OF ILLINOIS URBANA, IL (LIBRARY); URBANA, IL (NEWMARK)  
 UNIVERSITY OF MASSACHUSETTS (Heronemus), Amherst MA CE Dept  
 UNIVERSITY OF MICHIGAN Ann Arbor MI (Richart)  
 UNIVERSITY OF NEBRASKA-LINCOLN Lincoln, NE (Ross Ice Shelf Proj.)  
 UNIVERSITY OF TEXAS Inst. Marine Sci (Library), Port Arkansas TX  
 UNIVERSITY OF TEXAS AT AUSTIN AUSTIN, TX (THOMPSON)  
 UNIVERSITY OF WASHINGTON Dept of Civil Engr (Dr. Mattock), Seattle WA; Seattle WA (E. Linger);  
 Seattle, WA Transportation, Construction & Geom. Div  
 UNIVERSITY OF WISCONSIN Milwaukee WI (Ctr of Great Lakes Studies)  
 VIRGINIA INST. OF MARINE SCI Gloucester Point VA (Library)  
 AMSCO Dr. R. McCoy, Erie, PA  
 ARCAIR CO. D. Young, Lancaster OH  
 ARVID GRANT OLYMPIA, WA  
 ATLANTIC RICHFIELD CO. DALLAS, TX (SMITH)  
 BAGGS ASSOC. Beaufort, SC  
 BECHTEL CORP. SAN FRANCISCO, CA (PHELPS)  
 BELGIUM HAECON, N.V., Gent  
 BRITISH EMBASSY Sci. & Tech. Dept. (J. McAuley), Washington DC  
 BROWN & CALDWELL E M Saunders Walnut Creek, CA  
 BROWN & ROOT Houston TX (D. Ward)

CANADA Nova Scotia Rsch Found. Corp. Dartmouth, Nova Scotia; Surveyor, Nenninger & Chenevert Inc.,  
 Montreal; Trans-Mnt Oil Pipe Lone Corp. Vancouver, BC Canada  
 CHEMED CORP Lake Zurich IL (Dearborn Chem. Div.Lib.)  
 CHEVRON OIL FIELD RESEARCH CO. LA HABRA, CA (BROOKS)  
 COLUMBIA GULF TRANSMISSION CO. HOUSTON, TX (ENG. LIB.)  
 DESIGN SERVICES Beck, Ventura, CA  
 DIXIE DIVING CENTER Decatur, GA  
 DURLACH, O'NEAL, JENKINS & ASSOC. Columbia SC  
 EVALUATION ASSOC. INC KING OF PRUSSIA, PA (FEDELE)  
 EXXON PRODUCTION RESEARCH CO Houston TX (A. Butler Jr)  
 FORD, BACON & DAVIS, INC. New York (Library)  
 GRUMMAN AEROSPACE CORP. Bethpage NY (Tech. Info. Ctr)  
 HUGHES AIRCRAFT Culver City CA (Tech. Doc. Ctr)  
 JAMES CO. R. Girdley, Orlando FL  
 MARATHON OIL CO Houston TX  
 MCDONNELL AIRCRAFT CO. Dept 501 (R.H. Fayman), St Louis MO  
 MEDERMOTT & CO. Diving Division, Harvey, LA  
 MOFFATT & NICHOL ENGINEERS (R. Palmer) Long Beach, CA  
 NEWPORT NEWS SHIPBLDG & DRYDOCK CO. Newport News VA (Tech. Lib.)  
 NORWAY I. Foss, Oslo  
 PACIFIC MARINE TECHNOLOGY Long Beach, CA (Wagner)  
 PORTLAND CEMENT ASSOC. Skokie IL (Rsch & Dev Lab. Lib.)  
 RAYMOND INTERNATIONAL INC. E Colle Soil Tech Dept, Pennsauken, NJ  
 SANDIA LABORATORIES Albuquerque, NM (Vortman); Library Div., Livermore CA  
 SCHUPACK ASSOC SO. NORWALK, CT (SCHUPACK)  
 SEATECH CORP. MIAMI, FL (PERONI)  
 SHELL DEVELOPMENT CO. Houston TX (C. Sellars Jr.)  
 SHELL OIL CO. Houston TX (R. de Castongrene)  
 SWEDEN VBB (Library), Stockholm  
 TEXTRON INC BUFFALO, NY (RESEARCH CENTER LIB.)  
 TRW SYSTEMS CLEVELAND, OH (ENG. LIB.); REDONDO BEACH, CA (DAI)  
 UNITED KINGDOM Cement & Concrete Assoc Wexham Springs, Slough Bucks; D. New, G. Maunsell &  
 Partners, London; J. Derrington, London; Library, Bristol; R. Browne, Southall, Middlesex; Taylor,  
 Woodrow Constr (014P), Southall, Middlesex; Taylor, Woodrow Constr (Smith), Southall, Middlesex; Univ.  
 of Bristol (R. Morgan), Bristol  
 UNITED TECHNOLOGIES Windsor Locks CT (Hamilton Std Div., Library)  
 WARD, WOLSTENHOLD ARCHITECTS Sacramento, CA  
 WESTINGHOUSE ELECTRIC CORP. Library, Pittsburgh PA  
 WM CLAPP LABS - BATTELLE DUXBURY, MA (LIBRARY)  
 BRAHTZ La Jolla, CA  
 KETRON, BOB Ft Worth, TX  
 KRUZIC, T.P. Silver Spring, MD  
 LAYTON Redmond, WA  
 CAPT MURPHY Sunnyvale, CA  
 T.W. MERMEL Washington DC